



water system site
plan requirements
for revised total coliform rule

- 1 First service connection
- 2 Areas with previous coliform detections
- 3 Water tanks
- 4 Dead ends
- 5 Seasonal use areas
- 6 System interconnections